

Annexure C/

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 12/08/2025

It is certified that an inspection team headed by **Dr. Rakshita Singh, Block Development Officer, Jamalpur, Mirzapur** from PHED inspected the **Sunbeam Academy Knowledge Park, Baraipur, Jamalpur, Mirzapur** on **03/08/2025** (date of inspection) and on the basis of Water Test Report (Attached) dated **12/08/2025** (PHED Lab) certified that the **Sunbeam Academy Knowledge Park** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 11/08/2029

Signature with Seal:

Name : Dr. Rakshita Singh

Designation : Bock Developing Officer,
Jamalpur, Mirzapur

Name & Address of the Office / Department :

31.7.2025
प्रकाश अधिकारी
नीरजपुर

To

Sunbeam Academy Knowledge Park

Baraipur, Jamalpur, Mirzapur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

WATER TEST REPORT

SAMPLE SOURCE: SUNBEAM ACADEMY, KNOWLEGDE PARK, MIRZAPUR

TEST PROTOCOL: POTABLE WATER TEST

1. TURBIDITY	:	< 5 NTU
2. COLOUR	:	Colourless
3. TASTE & ODOUR	:	Un Objectionable
4. pH VALUE	:	7.4
5. TOTAL DISSOLVED SOLIDS	:	85 ppm.
6. CHLORIDES	:	08 ppm.
7. SULPHATES	:	Nil
8. FLUORIDE	:	Nil
9. NITRATES	:	1ppm
10. NITRITES	:	Nil
11. CALCIUM	:	20ppm.
12. MAGNESIUM	:	15ppm.
13. TOTAL HARDNESS AS CaCO ₃	:	40ppm.
14. IRON	:	0.02ppm.
15. RESIDUAL CHLORINE	:	Nil (R.O. Treated water)

Observations: All parameter suits to best potable water limits.

CONCLUSIVE RESULT: Sample was found to be fit for potable use

Signature with Date: 24/01/2025
खण्ड पानी कारबाह
जमालपुर